

## **Odenton Library Community Park**

Anne Arundel County Capital Project No. P584401

Office of Planning & Zoning Community Meeting for Discussion of Environmental Modifications and Impacts

Public Input Period: 6/21/-23 - 7/5/23

<u>Date Rec'd</u>	<u>Name</u>	<u>Comment/Question</u>	<u>Response</u>
6/21/23	D. Hill	Can the curbs being built be sloping rather than squared? We have a lot of wildlife (including turtles) and it allows them to move easily. Thanks!	Thank you for your input. We wil consider using a different AACo standard curb detail here called the "Mountable curb and gutter" which has a sloped edge rather than squared and should allow for turtle crossings.